MIAMI-DADE FIRE RESCUE DEPARTMENT - Inspection Report

Page 1 of 2



FIRE PREVENTION DIVISION 9300 NW 41 STREET, DORAL, FLORIDA 33178 PHONE 786.331.4800 FAX 786.331.4801



PERMIT#

00121-00072

Business Address: (District 44) DCPS F C MARTIN K-8 CENTER 14250-14250 BOGGS DR MIAMI, FL 33176

Billing Address:

DCPS F C MARTIN K-8 CENTER 1450 NE 2 AVE ROOM 602 MIAMI, FL 33132 **RESULT: Referred to State**

Resulted Date: 4/4/22

Permit Type: Education / Public Licensed Educ. Facility.

Inspection Month: March

Inspector: ILIE CAMINO 786-336-6838 ilieg@miamidade.gov

NOTICE OF VIOLATION AND ORDER TO CORRECT

The hazards noted herein are in violation of the Florida Fire Prevention Code and/or Miami-Dade County Code and are deemed to be threats to life safety and/or property. You are hereby ordered to comply with the corrective measures prescribed. Nothing in this report supersedes any previously written, still existing violations for this occupancy.

APPEALS

Any person who believes they were incorrectly issued a notice of violation or that the violation cited is not applicable to their occupancy classification or believes aggrieved by any action or decision of this code may appeal to the Miami-Dade County Fire Prevention and Safety Appeals Board by filing a written notice within 30 days of receiving the Notice of Violation and Order to Correct. The appeal request must be submitted in writing to the Secretary of the Board. Information on filing an appeal can be obtained on the web at: http://www.miamidade.gov/fire/request-appeal.asp.. Filing of a written notice of appeal shall not stay the effect of any such action or decision which is the subject to the appeal. Section 14-36, Code of Miami-Dade County

Please Note: A Life Safety Permit required by Section 14-39, Code of Miami-Dade County, to operate the above named occupancy will be issued upon correction of all outstanding violations and payment of fees assessed. Failure to obtain the required Life Safety Permit will result in enforcement actions including fines, citations, liens and/or orders to cease and desist operation.

Viol.	Date Created	Comply by Date	Violation, Correction & Comments Failure to comply with below violations will result in issuance of a citation
1	2/28/22	3/30/22	Violation: FFPC 7th Edition, NFPA 1:. 13.7.4.4 Fire Alarm. Annual. Inspection, Testing & Maintenance. Failure to provide documentation of inspection, testing and maintenance of fire alarm system Correction: Provide current annual fire alarm system inspection report to inspector/AHJ, testing and maintenance reports free of deficiencies or impairments; provide documentation of correction of any deficiencies or impairments found therein Comments: PROVIDE FIRE ALARM FREE OF DEFICIENCIES EMAIL ilie.camino@miamidade.gov.
2	2/28/22	3/30/22	Violation: Code of Miami-Dade County. 14-61(D) Runner Service and Service Contracts. Failure to provide runner service Correction: Provide a Runner Service and Service Contracts. All fire alarm systems shall be required to have in effect at all times a service contract with a licensed fire alarm service contractor, a listed fire alarm service-local company or a listed central station to provide all maintenance, service and testing as required by this Code. (1) The service contract shall include a provision for runner service available to respond to the protected premises at any and all times within two (2) hours of notification of the runner service of any alarm or supervisory signal, and within four (4) hours of notification of any trouble signal Comments: PROVIDE RUNNER SERVICE EMAIL ilie.camino@yhaoo.com.



MIAMI-DADE FIRE RESCUE DEPARTMENT - Inspection Report							
3	5/4/21	6/3/21	Violation: FFPC 6th Edition, NFPA 1:. 13.3.3.2 Fire Sprinkler System. Annual Inspection. Failure to have fire sprinkler system inspected and tested Correction: Provide current annual fire sprinkler system inspection report to inspector/AHJ, testing and maintenance reports free of deficiencies or impairments; provide documentation of correction of any deficiencies or impairments found therein Comments: Provide annual fire sprinkler system report showing no deficiencies email to	U			
4	3/4/20	4/3/20	ilie.camino@miamidade.gov. Violation: FFPC 6th Edition, NFPA 1:. 13.3.3.4.1.5.1 Fire Sprinkler. Correction and Repairs.				
			Failure to correct or repair deficiencies or impairments noted on current fire sprinkler inspection report Correction: The property owner or designated representative shall correct or repair				
			deficiencies or impairments that are found during the inspection, test, and maintenance required by this Code. [25:4.1.5.1]. Comments: replace fire riser gauge (900 bldg).				

CUSTOMER SIGNATURE

Title: Agency Name:

Please Note: A life safety permit will be issued upon compliance of outstanding violations and payment of fees assesed. One (1) re-inspection will be performed at no additional cost. All subsequent re-inspections will be billed at one-half the original permit fee amount.

